

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
SAN FRANCISCO BAY REGION

ORDER NO. 90-022
NPDES NO. CA0038253

WASTE DISCHARGE REQUIREMENTS FOR:

EAST BAY MUNICIPAL UTILITY DISTRICT
SAN PABLO FILTER PLANT
KENSINGTON, CONTRA COSTA COUNTY

The California Regional Water Quality Control Board, San Francisco Bay Region, (hereinafter Board) finds that:

1. East Bay Municipal Utility District, hereinafter discharger, by application, dated June 15, 1989, has applied for renewal of waste discharge requirements and a permit to discharge waste under the National Pollutant Discharge Elimination System (NPDES).
2. The discharger treats and produces between 10 and 15 million gallons per day. Since 1984, the discharger has operated intermittently (30-180 days/year). Treatment consists of aeration, chemical coagulation, sedimentation, filtration, disinfection and fluoridation. Chlorine, aluminum sulfate, cationic polymer, activated carbon, potassium permanganate, caustic soda and fluoride are added in the treatment process. The treatment generates wastewaters discharged by the following operating procedures:

- a. A 2.8 million gallon sedimentation basin is drained every five weeks. The supernatant and sludge are normally discharged to the washwater settling basin, allowed to settle, then the supernatant is recycled with the incoming raw water. When problems occur, such as tastes and odors, the washwater settling basin supernatant is discharged through Outfall E-001 to Cerrito Creek.

Three filters per day are backwashed which generates a total of 200,000 gallons of backwash water per day. Normally, the backwash water is held in the washwater basin for settling and then recycled with the incoming raw water. When problems occur, such as tastes and odors, backwash supernatant from the washwater settling basin is also discharged through Outfall E-001 to Cerrito Creek.

- b. Sludge from the sedimentation basins and from the washwater basins is discharged to the sanitary sewer system where it flows to the District's SD-1 wastewater treatment plant. The sludge discharge rate is 0.5 to 1.0

mgd. During periods of shutdown, the tunnel supplying water to the treatment plant fills because the shutoff valve is at the terminal end of the tunnel. It is proposed that whenever this raw water and tunnel blow-off which results during startup meet the requirements of surface discharge, that this water be discharged to the creek via E-001.

3. Outfall E-001 discharges to Cerrito Creek. Outfall E-001 is a 2 feet by 3 feet rectangular concrete conduit (Latitude 37 deg., 53 min., 54.8 sec.; Longitude 122 deg., 18 min., 06.2 sec.).
4. The discharge is presently governed by Waste Discharge Requirements, Order No. 85-5, which allow discharge into San Francisco Bay.
5. The Regional Board adopted a revised Water Quality Control Plan for the San Francisco Bay Region (Basin Plan) on December 17, 1986. The Basin Plan contains water quality objectives for Cerrito Creek, San Francisco Bay and contiguous waters.
6. The beneficial uses of Cerrito Creek, San Francisco Bay and contiguous water bodies are:
 - a. Water contact recreation
 - b. Non-contact water recreation
 - c. Wildlife habitat
 - d. Preservation of rare and endangered species
 - e. Estuarine and warm fresh water habitat
 - f. Fish migration and spawning
 - g. Industrial service supply
 - h. Shellfish harvesting
 - i. Navigation
 - j. Commercial and sport fishing
7. The discharge to Cerrito Creek violates the Basin Plan's prohibitions against discharge of any wastewater which has characteristics of concern to beneficial uses into nontidal waters and at any point at which the wastewater does not receive a minimum initial dilution of at least 10:1.
8. The discharge of wastewater in compliance with the requirements of this order qualifies for an exception to the Basin Plan prohibitions because an inordinate burden would be placed on the discharger relative to the beneficial uses protected. Also, an equivalent level of environmental protection will be achieved by the high quality of wastewater required by this Order for discharge.
9. This Order serves as an NPDES permit, adoption of which is exempt from the provisions of Chapter 3 (commencing with Section 21100) of Division 13 of the Public Resources Code

(CEQA) pursuant to Section 13389 of the California Water Code.

10. The discharger and interested agencies and persons have been notified of the Board's intent to reissue requirements for the existing discharge and have been provided with the opportunity for a public hearing and an opportunity to submit their written views and recommendations.
11. The Board, in a public meeting, heard and considered all comments pertaining to the discharge.

IT IS HEREBY ORDERED THAT East Bay Municipal Utility District, in order to meet the provisions contained in Division 7 of the California Water Code and regulations adopted thereunder, and the provisions of the Clean Water Act as amended and regulations and guidelines adopted thereunder, shall comply with the following:

A. Discharge Prohibitions

1. Discharge of wastewater through Outfall E-001 is prohibited except when problems such as tastes and odors occur.
2. No sludge shall be discharged into watercourses or waters of the State.
3. There shall be no bypass of untreated wastewater to waters of the State.

B. Effluent Limitations

1. Effluent discharged shall not exceed the following limits:

<u>Constituents</u>	<u>Units</u>	<u>30-day Average</u>	<u>Daily</u>	<u>Instantaneous Maximum</u>
a. Total Suspended Solids	mg/l	15	30	--
b. Settleable Matter	ml/l-hr	0.1	0.2	--
c. Total Chlorine residual (1)	mg/l	--	--	0.0
d. Aluminum Dissolved	mg/l	--	--	0.75

(1) Requirement defined as below limit of detection in standard test methods.

2. Waste shall not have a pH of less than 6.5 nor greater than 8.5, unless the raw influent water being filtered has a pH greater than 8.5, in which case the waste shall

not have a pH greater than that of the influent water.

3. In any representative set of samples, the waste as discharged shall meet the following limit of quality:

TOXICITY: The survival of test fishes in 96 hour bioassays of the effluent discharged shall be a median of 90 % survival and a 90 percentile value of not less than 70 % survival.

C. Receiving Water Limitations

1. The discharge of waste shall not cause the following conditions to exist in waters of the State at any point.
 - a. Floating, suspended, or deposited macroscopic particulate matter or foam;
 - b. Bottom deposits or aquatic growths;
 - c. Alteration of temperature, turbidity, or apparent color beyond present natural background levels;
 - d. Increased turbidity above background levels by more than the following:

<u>Receiving Water Background</u>	<u>Incremental Increase</u>
<50 units (NTU)	5 units, maximum
50 - 100 units	10 units, maximum
>100 units	10 % of background, maximum

- e. Visible, floating, suspended, or deposited oil or other products of petroleum origin;
 - f. Toxic or other deleterious substances to be present in concentrations or quantities which will cause deleterious effects on aquatic biota, wildlife, or waterfowl, or which render any of this unfit for human consumption either at levels created in the receiving waters or as a result of biological concentration.
2. The discharge of waste shall not cause the following limits to be exceeded in waters of the State in any place whithin one foot of the water surface:
 - a. Dissolved Oxygen 5.0 mg/l minimum. Median of any three consecutive months shall not be less than 80 %

saturation. When natural factors cause lesser concentration(s) than those specified above, then this discharge shall not cause further reduction in the concentration of dissolved oxygen.

- b. Dissolved Sulfide 0.1 mg/l maximum
- c. pH Variation from natural ambient pH by more than 0.5 pH units.
- d. Un-ionized Ammonia 0.025 mg/l as N Annual Median;
0.4 mg/l as N Maximum.

- 3. The discharge shall not cause a violation of any applicable water quality standard for receiving waters adopted by the Board or the State Water Resources Control Board as required by the Clean Water Act and regulations adopted thereunder. If more stringent applicable water quality standards are promulgated or approved pursuant to Section 303 of the Clean Water Act, or amendments thereto, the Board will revise and modify this Order in accordance with such more stringent standards.

D. Provisions


- 1. The requirements prescribed by this Order supersede the requirements prescribed by Order No. 85-5 adopted on January 16, 1985. Order No. 85-5 is hereby rescinded.
- 2. Where concentration limitations in mg/l are contained in this permit, the following mass emission limitations shall also apply as follows:

$$\text{Mass Emission Limit in lbs/day} = \text{Concentration Limit in mg/l} \times 8.34 \times \text{Actual Flow in mgd averaged over the time interval to which the limit applies.}$$
- 3. The discharger shall comply with all sections of this Order upon adoption.
- 4. The discharger shall comply with the self-monitoring program as adopted by the Board and as may be amended by the Executive Officer.
- 5. The discharger shall review and update by December 31, annually, its contingency plan as required by Board Resolution No. 74-10. The discharge of pollutants in

violation of this Order where the discharger has failed to develop and/or implement a contingency plan will be basis for considering such discharge a willfull and negligent violation of this Order pursuant to Section 13387 if the California Water Code.

6. The discharger shall comply with all applicable items of the attached "Standard Provisions, Reporting Requirements and Definitions" dated December 1986.
7. This Order expires February 21, 1995. The discharger must file a report of waste discharge in accordance with Title 23, Chapter 3, Subchapter 9 of the California Administrative Code not later than 180 days in advance of such expiration date as applicable for issuance of new waste discharge requirements.
8. This Order shall serve as a National Pollutant Discharge Elimination System Permit pursuant to Section 402 of the Clean Water Act or amendments thereto, and shall become effective 10 days after date of its adoption provided the Regional Administrator, Environmental Protection Agency, has no objection. If the Regional Administrator objects to its issuance, the permit shall not become effective until such objection is withdrawn.

I, Steven R. Ritchie, Executive Officer do hereby certify the foregoing is a full, true and correct copy of an Order adopted by the California Regional Water Quality Board, San Francisco Bay Region on February 21, 1990.



STEVEN R. RITCHIE
Executive Officer

Attachments:
Standard Provisions & Reporting
Requirements, December 1986
Self-Monitoring Program
Resolution 74-10

[File No. 2119.1111]
[Originator/MJR]
[Reviewer/RJC]

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
SAN FRANCISCO BAY REGION

SELF-MONITORING PROGRAM
FOR

EAST BAY MUNICIPAL UTILITY DISTRICT

SAN PABLO FILTER PLANT

KENSINGTON, CONTRA COSTA COUNTY

NPDES NO. CA0038253

ORDER NO. 90-022

H. MONITORING SPECIFICATIONS

1. Description of Sampling Stations

a. Intake
Station

Description

I-1

At any point in the raw water supply prior to any treatment.

b. Effluent
Station

Description

E-001

At any point in the Outfall Pipe E-001.

c. Receiving Waters
Station

Description

C-1

At a point in Cerrito Creek, located approximately 100 feet upstream from Outfall E-001 point of discharge.

C-2

At a point in Cerrito Creek, located approximately 25 feet downstream from Outfall E-001 point of discharge.

2. Schedule of Sampling and Analysis

- a. The schedule of sampling and analysis shall be that given as Table I.

I, Steven R. Ritchie, Executive Officer, do hereby certify that the foregoing Self-Monitoring Program:

1. Has been developed in accordance with the procedure set forth in this Regional Board's Resolution No. 73-16 in order to obtain data and document compliance with waste discharge requirements established in Regional Board Order No. 90-022.
2. Is effective on the date shown below.
3. May be reviewed at any time subsequent to the effective date upon written notice from the Executive Officer or request from the discharger, and revisions will be ordered by the Executive Officer.

Attachments:
Table 1



STEVEN R. RITCHIE
Executive Officer
Effective Date 2/21/90

TABLE I

SCHEDULE FOR SAMPLING, MEASUREMENTS, AND ANALYSES

NPDES # CA0038253

ORDER NO. 90-022

SAMPLING STATIONS	E-001		C-1 & C-2		I		
TYPE OF SAMPLES	C-24	G	G	O	G		
Flow Rate (mgd)		(1) D					
Settleable Matter (ml/l-hr)		D					
Total Suspended Solids (mg/l & lbs/day)		D					
Aluminum dissolved (mg/l & lbs/day)		Y					
Chlorine Residual (mg/l)		D					
pH (units)		D	D		D		
Fish Toxicity, 96-hour % Survival in undiluted waste		Y					
Turbidity (Nephelometric Turbidity Units)		D	D				
All Applicable Standard Observations				D			

LEGEND FOR TABLETYPES OF SAMPLES

G = grab sample
 C-24 = composite sample - 24-hour
 O = observation

FREQUENCY OF SAMPLING

Y = yearly, during the first calendar quarter
 W = weekly
 M = monthly
 D = daily when there is a discharge.

TYPES OF STATIONS

I = intake and/or water
 supply stations
 E = waste effluent stations
 C = receiving water stations

(1) An estimate is acceptable. Basis of calculation shall be stated